



WOODLYNNE SCHOOL DISTRICT



131 ELM AVENUE, WOODLYNNE, NJ 08107
(856) 962-8822 Fax (856) 962-0191

Jack McCulley, Ed.D.
Interim Superintendent/Principal

Sharon Vogel
President, Board of Education

To Woodlynne Parents and Community:

In July 2016, the State Board of Education adopted regulations regarding testing for lead in drinking water in public schools throughout New Jersey. The regulations require testing for lead in all drinking water outlets within the 2016-2017 school year. All districts developed a plan to sample the lead in the water at the school. The samples had to be sent to a certified laboratory for analysis. Once the results were available to the school, they must be made public on the school website and to parents.

The Woodlynne School District completed the lead testing on February 15, 2017. The results are posted on the school website and can be found on the back of this letter. The results of the lead analysis show that all samples came back under 2.00 ug/L. The school would need to take action if the results were above 15.5 ug/L. With the current results there is no need for any further action to be taken by the Woodlynne School District because the levels are below areas of concern or need for remediation.

Providing a safe environment for the students of Woodlynne is of the utmost importance to Woodlynne School District. We will continue to not only comply with mandates about school safety from the state of New Jersey but proactively address any areas of concern. If you have any questions about the lead testing that took place or any other concerns about safety at the Woodlynne School District, please do not hesitate to reach out to the administration. Thank you for your continued support of the Woodlynne School District.

Sincerely,

Jack McCulley, Ed.D.
Interim Superintendent/Principal
Woodlynne School District



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Woodlynne Public School

131 Elm Avenue
Woodlynne, NJ 08107

Results of Lead Analysis

Date & Time First Draw Sampled: 02/15/2017 05:04 - 05:25

Date & Time Analyzed: 02/22/2017 11:38 - 13:07


Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
WDL-WC-01-HALL1	<2.00	15.5
WDL-WC-02-HALL1	<2.00	15.5
WDL-WC-03-HALL	<2.00	15.5
WDL-WC-01-NURSE	<2.00	15.5
WDL-WC-01-HALL2	<2.00	15.5
WDL-KC-01-KITCH	<2.00	15.5
WDL-DW-01-RM1	<2.00	15.5
WDL-DW-01-RM4	<2.00	15.5
WDL-DW-01-RM2	<2.00	15.5
WDL-DW-01-RM3	<2.00	15.5
WDL-WC-02-HALL2	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

2-23-17
Date